

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (0999)		60 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
Asbestos (1094)		1 routine (RT) per nine years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
500 SOUTH BROAD ST (MWDA500)	1/1/11 - 12/31/19		Complete
	1/1/20 - 12/31/28		
Total Coliform (3100)		60 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Disinfectant Byproducts - TTHM & HAA5 (DBP)		8 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
25 SCHWINKS DR (MWDBACT033)	10/1/18 - 12/31/18	11/1-11/30	Complete
	1/1/19 - 3/31/19	2/1-2/28	Complete
	4/1/19 - 6/30/19	5/1-5/31	
	7/1/19 - 9/30/19	8/1-8/31	
130 HIGH HILL RD (MWDBACT036)	10/1/18 - 12/31/18	11/1-11/30	Complete
	1/1/19 - 3/31/19	2/1-2/28	Complete
	4/1/19 - 6/30/19	5/1-5/31	
	7/1/19 - 9/30/19	8/1-8/31	
528 JOHNSON AVE (MWDBB100)	10/1/18 - 12/31/18	11/1-11/30	Complete
	1/1/19 - 3/31/19	2/1-2/28	Complete
	4/1/19 - 6/30/19	5/1-5/31	
	7/1/19 - 9/30/19	8/1-8/31	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Disinfectant Byproducts - TTHM & HAA5 (DBP)		8 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
343 WEST MAIN ST (MWDBB300)	10/1/18 - 12/31/18	11/1-11/30	Complete
	1/1/19 - 3/31/19	2/1-2/28	Complete
	4/1/19 - 6/30/19	5/1-5/31	
	7/1/19 - 9/30/19	8/1-8/31	
285 PRESTON AVE (MWDBH200)	10/1/18 - 12/31/18	11/1-11/30	Complete
	1/1/19 - 3/31/19	2/1-2/28	Complete
	4/1/19 - 6/30/19	5/1-5/31	
	7/1/19 - 9/30/19	8/1-8/31	
168 CHAMBERLAIN HWY (MWDEL200)	10/1/18 - 12/31/18	11/1-11/30	Complete
	1/1/19 - 3/31/19	2/1-2/28	Complete
	4/1/19 - 6/30/19	5/1-5/31	
	7/1/19 - 9/30/19	8/1-8/31	
55 MICHAEL DR (MWDEL300)	10/1/18 - 12/31/18	11/1-11/30	Complete
	1/1/19 - 3/31/19	2/1-2/28	Complete
	4/1/19 - 6/30/19	5/1-5/31	
	7/1/19 - 9/30/19	8/1-8/31	
664 WEST MAIN ST (MWDM1000)	10/1/18 - 12/31/18	11/1-11/30	Complete
	1/1/19 - 3/31/19	2/1-2/28	Complete
	4/1/19 - 6/30/19	5/1-5/31	
	7/1/19 - 9/30/19	8/1-8/31	
Lead And Copper (PBCU)		30 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/18 - 12/31/18	6/1-9/30	Complete
	1/1/19 - 12/31/19	6/1-9/30	
	1/1/20 - 12/31/20	6/1-9/30	
Physical Parameters (PPS)		60 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)	60 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	10/1/19 - 10/31/19		

Water System Facility: **MERIMERE WTP ENTRY POINT (WSF ID: 00700)**

Dibromochloropropane (DBCP) (2931)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MERIMERE (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		

Ethylene Dibromide (EDB) (2946)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MERIMERE (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MERIMERE (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MERIMERE (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MERIMERE (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Inorganic Chemicals (IOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MERIMERE (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MERIMERE (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MERIMERE (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Monitoring Requirements

Water System Facility: MERIMERE WTP ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - MERIMERE (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Water System Facility: ELMERE WTP ENTRY POINT (WSF ID: 00701)

Net Gross Alpha (4000)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - ELMERE (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Uranium (4006)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - ELMERE (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Combined Radium-226/228 (4010)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - ELMERE (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Inorganic Chemicals (IOCS)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - ELMERE (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - ELMERE (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - ELMERE (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - ELMERE (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Water System Facility: BROAD BROOK WTP ENTRY POINT (WSF ID: 00702)

Inorganic Chemicals (IOCS)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Monitoring Requirements

Water System Facility: **BROAD BROOK WTP ENTRY POINT (WSF ID: 00702)**

Inorganic Chemicals (IOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BROAD BROOK (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BROAD BROOK (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BROAD BROOK (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BROAD BROOK (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BROAD BROOK (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Water System Facility: **BRADLEY HUBBARD WTP ENTRY POINT (WSF ID: 00703)**

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BRADLEY HUBBARD (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BRADLEY HUBBARD (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BRADLEY HUBBARD (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BRADLEY HUBBARD (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Monitoring Requirements

Water System Facility: **BRADLEY HUBBARD WTP ENTRY POINT (WSF ID: 00703)**

Inorganic Chemicals (IOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/20		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BRADLEY HUBBARD (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BRADLEY HUBBARD (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BRADLEY HUBBARD (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Water System Facility: **EVANSVILLE WTP ENTRY POINT (WSF ID: 00704)**

Nickel (1036)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EVANSVILLE (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EVANSVILLE (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EVANSVILLE (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EVANSVILLE (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EVANSVILLE (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Monitoring Requirements

Water System Facility: EVANSVILLE WTP ENTRY POINT (WSF ID: 00704)

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EVANSVILLE (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EVANSVILLE (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EVANSVILLE (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		

Water System Facility: MULE WELL WTP ENTRY POINT (WSF ID: 00705)

Net Gross Alpha (4000) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MULE WELL (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Uranium (4006) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MULE WELL (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Combined Radium-226/228 (4010) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MULE WELL (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MULE WELL (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MULE WELL (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MULE WELL (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Monitoring Requirements

Water System Facility: MULE WELL WTP ENTRY POINT (WSF ID: 00705)

Organic Chemicals (VOCS)	Monitoring Period	Collection Period	Compliance Status
<i>Sampling Point (Sampling Point ID)</i>			
EP - MULE WELL (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Water System Facility: COLUMBUS PARK WELL WTP ENTRY POINT (WSF ID: 00706)

Net Gross Alpha (4000)	Monitoring Period	Collection Period	Compliance Status
<i>Sampling Point (Sampling Point ID)</i>			
EP - COLUMBUS PARK (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Uranium (4006)	Monitoring Period	Collection Period	Compliance Status
<i>Sampling Point (Sampling Point ID)</i>			
EP - COLUMBUS PARK (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Combined Radium-226/228 (4010)	Monitoring Period	Collection Period	Compliance Status
<i>Sampling Point (Sampling Point ID)</i>			
EP - COLUMBUS PARK (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Inorganic Chemicals (IOCS)	Monitoring Period	Collection Period	Compliance Status
<i>Sampling Point (Sampling Point ID)</i>			
EP - COLUMBUS PARK (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Nitrate And Nitrite (NOX)	Monitoring Period	Collection Period	Compliance Status
<i>Sampling Point (Sampling Point ID)</i>			
EP - COLUMBUS PARK (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	Monitoring Period	Collection Period	Compliance Status
<i>Sampling Point (Sampling Point ID)</i>			
EP - COLUMBUS PARK (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS)	Monitoring Period	Collection Period	Compliance Status
<i>Sampling Point (Sampling Point ID)</i>			
EP - COLUMBUS PARK (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Water System Facility: PLATT LINCOLN WTP ENTRY POINT (WSF ID: 00707)

Dibromochloropropane (DBCP) (2931)	Monitoring Period	Collection Period	Compliance Status
<i>Sampling Point (Sampling Point ID)</i>			
EP - PLATT LINCOLN (3)	1/1/18 - 12/31/18		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Monitoring Requirements

Water System Facility: PLATT LINCOLN WTP ENTRY POINT (WSF ID: 00707)

Dibromochloropropane (DBCP) (2931)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Ethylene Dibromide (EDB) (2946)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PLATT LINCOLN (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PLATT LINCOLN (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PLATT LINCOLN (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PLATT LINCOLN (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PLATT LINCOLN (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PLATT LINCOLN (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PLATT LINCOLN (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PLATT LINCOLN (3)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Out of Service
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Monitoring Requirements

Water System Facility: **MULE WELL (WSF ID: 1355)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
MULE WELL (2)	4/1/19 - 4/30/19		Complete
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: **COLUMBUS PARK WELL (WSF ID: 1356)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
COLUMBUS PARK WELL (2)	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		

Water System Facility: **PLATT WELL (WSF ID: 1357)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
PLATT WELL (2)	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: **LINCOLN WELL (WSF ID: 1358)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LINCOLN WELL (2)	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Out of Service
	2/1/19 - 2/28/19		Out of Service
	3/1/19 - 3/31/19		Out of Service
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Monitoring Requirements

Water System Facility: LINCOLN WELL (WSF ID: 1358)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	10/1/19 - 10/31/19		

Water System Facility: EVANSVILLE AVENUE WEST WELL (WSF ID: 1359)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EVANSVILLE AVENUE WE (2)	11/1/18 - 11/30/18		Out of Service
	12/1/18 - 12/31/18		Out of Service
	1/1/19 - 1/31/19		Out of Service
	2/1/19 - 2/28/19		Out of Service
	3/1/19 - 3/31/19		Out of Service
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: EVANSVILLE AVENUE EAST WELL (WSF ID: 1360)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EVANSVILLE AVENUE EA (2)	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Out of Service
	3/1/19 - 3/31/19		Out of Service
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: BROAD BROOK WATER TREATMENT PLANT (WSF ID: 150)

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CFE - BROAD BROOK TP (5)	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Monitoring Requirements

Water System Facility: **BROAD BROOK WATER TREATMENT PLANT (WSF ID: 150)**

Total Organic Carbon (2920)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
	3/1/19 - 3/31/19		Complete	
	4/1/19 - 4/30/19			
	5/1/19 - 5/31/19			
	6/1/19 - 6/30/19			
	7/1/19 - 7/31/19			
	8/1/19 - 8/31/19			
	9/1/19 - 9/30/19			
	10/1/19 - 10/31/19			

Water System Facility: **MERIMERE WATER TREATMENT PLANT (WSF ID: 152)**

Total Organic Carbon (2920)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
CFE - MERIMERE WTP (5)	11/1/18 - 11/30/18		Complete	
	12/1/18 - 12/31/18		Complete	
	1/1/19 - 1/31/19		Complete	
	2/1/19 - 2/28/19		Complete	
	3/1/19 - 3/31/19		Complete	
	4/1/19 - 4/30/19			
	5/1/19 - 5/31/19			
	6/1/19 - 6/30/19			
	7/1/19 - 7/31/19			
	8/1/19 - 8/31/19			
	9/1/19 - 9/30/19			
	10/1/19 - 10/31/19			

Water System Facility: **ELMERE WATER TREATMENT PLANT (WSF ID: 153)**

Total Organic Carbon (2920)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
CFE - ELMERE WTP (5)	11/1/18 - 11/30/18		Complete	
	12/1/18 - 12/31/18		Complete	
	1/1/19 - 1/31/19		Complete	
	2/1/19 - 2/28/19		Complete	
	3/1/19 - 3/31/19		Complete	
	4/1/19 - 4/30/19			
	5/1/19 - 5/31/19			
	6/1/19 - 6/30/19			
	7/1/19 - 7/31/19			
	8/1/19 - 8/31/19			
	9/1/19 - 9/30/19			
	10/1/19 - 10/31/19			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Monitoring Requirements

Water System Facility: **BRADLEY HUBBARD WATER TREATMENT PLANT (WSF ID: 154)**

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CFE - BRADLEY WTP (5)	11/1/18 - 11/30/18		Out of Service
	12/1/18 - 12/31/18		Out of Service
	1/1/19 - 1/31/19		Out of Service
	2/1/19 - 2/28/19		Out of Service
	3/1/19 - 3/31/19		Out of Service
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: **BRADLEY HUBBARD RESERVOIR (WSF ID: 2139)**

Total Alkalinity (1927)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BRADLEY HUBBARD RES (1)	11/1/18 - 11/30/18		Out of Service
	12/1/18 - 12/31/18		Out of Service
	1/1/19 - 1/31/19		Out of Service
	2/1/19 - 2/28/19		Out of Service
	3/1/19 - 3/31/19		Out of Service
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BRADLEY HUBBARD RES (1)	11/1/18 - 11/30/18		Out of Service
	12/1/18 - 12/31/18		Out of Service
	1/1/19 - 1/31/19		Out of Service
	2/1/19 - 2/28/19		Out of Service
	3/1/19 - 3/31/19		Out of Service
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Monitoring Requirements

Water System Facility: **BRADLEY HUBBARD RESERVOIR (WSF ID: 2139)**

Total Organic Carbon (2920)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BRADLEY HUBBARD RES (1)	10/1/18 - 12/31/18		Out of Service
	1/1/19 - 3/31/19		Out of Service
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BRADLEY HUBBARD RES (1)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Surface Water Color and Turbidity (RPPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BRADLEY HUBBARD RES (1)	10/1/18 - 12/31/18		Out of Service
	1/1/19 - 3/31/19		Out of Service
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Surface Water Pesticides (RSOC)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BRADLEY HUBBARD RES (1)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Water System Facility: MERIMERE RESERVOIR (WSF ID: 2141)			
Total Alkalinity (1927)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
MERIMERE RESERVOIR (1)	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Monitoring Requirements

Water System Facility: MERIMERE RESERVOIR (WSF ID: 2141)

Total Alkalinity (1927)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Total Organic Carbon (2920)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
MERIMERE RESERVOIR (1)	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Total Coliform (3100)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
MERIMERE RESERVOIR (1)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		Complete
	7/1/19 - 9/30/19		
Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
MERIMERE RESERVOIR (1)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Surface Water Color and Turbidity (RPPS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
MERIMERE RESERVOIR (1)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		Complete
	7/1/19 - 9/30/19		
Surface Water Pesticides (RSOC)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
MERIMERE RESERVOIR (1)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Monitoring Requirements

Water System Facility: **BROAD BROOK RESERVOIR (WSF ID: 2142)**

Total Alkalinity (1927)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
BROAD BROOK RES (1)	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Total Organic Carbon (2920)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
BROAD BROOK RES (1)	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Total Coliform (3100)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
BROAD BROOK RES (1)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		Complete
	7/1/19 - 9/30/19		
Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
BROAD BROOK RES (1)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Monitoring Requirements

Water System Facility: **BROAD BROOK RESERVOIR (WSF ID: 2142)**

Surface Water Color and Turbidity (RPPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BROAD BROOK RES (1)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		Complete
	7/1/19 - 9/30/19		

Surface Water Pesticides (RSOC)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BROAD BROOK RES (1)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Water System Facility: **ELMERE RESERVOIR (WSF ID: 2145)**

Total Alkalinity (1927)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ELMERE RESERVOIR (1)	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ELMERE RESERVOIR (1)	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Monitoring Requirements

Water System Facility: ELMERE RESERVOIR (WSF ID: 2145)

Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ELMERE RESERVOIR (1)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		Complete
	7/1/19 - 9/30/19		
Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ELMERE RESERVOIR (1)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Surface Water Color and Turbidity (RPPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ELMERE RESERVOIR (1)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		Complete
	7/1/19 - 9/30/19		
Surface Water Pesticides (RSOC)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ELMERE RESERVOIR (1)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: MERIMERE WTP ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily	
Start Date: 7/1/2003	Compliance History:	Operating Limit	Monitoring	
	Monitoring Period	Compliance Status:	Compliance Status:	
	11/1/2018 - 11/30/2018	Y	Y	
	12/1/2018 - 12/31/2018	Y	Y	
	1/1/2019 - 1/31/2019	Y	Y	
	2/1/2019 - 2/28/2019	Y	Y	
	3/1/2019 - 3/31/2019	Y	Y	
	4/1/2019 - 4/30/2019			
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.1 PH	Daily	
Start Date: 7/1/2003	Compliance History:	Operating Limit	Monitoring	
	Monitoring Period	Compliance Status:	Compliance Status:	
	11/1/2018 - 11/30/2018	Y	Y	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Water System Facility: MERIMERE WTP ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.1 PH	Daily
Start Date: 7/1/2003			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.75 MG/L	2
Start Date: 7/1/2003			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

Water System Facility: ELMERE WTP ENTRY POINT (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 7/1/2003			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.1 PH	Daily
Start Date: 7/1/2003			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Water System Facility: **ELMERE WTP ENTRY POINT (WSFID: 00701)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.75 MG/L	2
Start Date: 7/1/2003			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

Water System Facility: **BROAD BROOK WTP ENTRY POINT (WSFID: 00702)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 7/1/2003			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.1 PH	Daily
Start Date: 7/1/2003			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.75 MG/L	2
Start Date: 7/1/2003			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Water System Facility: BRADLEY HUBBARD WTP ENTRY POINT (WSFID: 00703)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 7/1/2003			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	Offline 11/1/2018 - 11/30/2018	n/a	Y
	Offline 12/1/2018 - 12/31/2018	n/a	Y
	Offline 1/1/2019 - 1/31/2019	n/a	Y
	Offline 2/1/2019 - 2/28/2019	n/a	Y
	Offline 3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.1 PH	Daily
Start Date: 7/1/2003			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	Offline 11/1/2018 - 11/30/2018	n/a	Y
	Offline 12/1/2018 - 12/31/2018	n/a	Y
	Offline 1/1/2019 - 1/31/2019	n/a	Y
	Offline 2/1/2019 - 2/28/2019	n/a	Y
	Offline 3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.75 MG/L	2
Start Date: 7/1/2004			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	Offline 11/1/2018 - 11/30/2018	n/a	Y
	Offline 12/1/2018 - 12/31/2018	n/a	Y
	Offline 1/1/2019 - 1/31/2019	n/a	Y
	Offline 2/1/2019 - 2/28/2019	n/a	Y
	Offline 3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		

Water System Facility: EVANSVILLE WTP ENTRY POINT (WSFID: 00704)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 6/1/2005			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	Offline 2/1/2019 - 2/28/2019	n/a	Y
	Offline 3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Water System Facility: **EVANSVILLE WTP ENTRY POINT (WSFID: 00704)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 7/1/2003			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
Offline	2/1/2019 - 2/28/2019	n/a	Y
Offline	3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.8 PH	Daily
Start Date: 7/1/2003			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
Offline	2/1/2019 - 2/28/2019	n/a	Y
Offline	3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.75 MG/L	2
Start Date: 7/1/2003			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
Offline	2/1/2019 - 2/28/2019	n/a	Y
Offline	3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		

Water System Facility: **MULE WELL WTP ENTRY POINT (WSFID: 00705)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 6/1/2005			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
Offline	11/1/2018 - 11/30/2018	n/a	Y
Offline	12/1/2018 - 12/31/2018	n/a	Y
Offline	1/1/2019 - 1/31/2019	n/a	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Water System Facility: MULE WELL WTP ENTRY POINT (WSFID: 00705)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 7/1/2003			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
Offline	11/1/2018 - 11/30/2018	n/a	Y
Offline	12/1/2018 - 12/31/2018	n/a	Y
Offline	1/1/2019 - 1/31/2019	n/a	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.8 PH	Daily
Start Date: 7/1/2003			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
Offline	11/1/2018 - 11/30/2018	n/a	Y
Offline	12/1/2018 - 12/31/2018	n/a	Y
Offline	1/1/2019 - 1/31/2019	n/a	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 1/1/2004			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
Offline	11/1/2018 - 11/30/2018	n/a	Y
Offline	12/1/2018 - 12/31/2018	n/a	Y
Offline	1/1/2019 - 1/31/2019	n/a	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

Water System Facility: COLUMBUS PARK WELL WTP ENTRY POINT (WSFID: 00706)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 6/1/2005			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
Offline	11/1/2018 - 11/30/2018	n/a	Y
Offline	12/1/2018 - 12/31/2018	n/a	Y
Offline	1/1/2019 - 1/31/2019	n/a	Y
Offline	2/1/2019 - 2/28/2019	n/a	Y
Offline	3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Water System Facility: **COLUMBUS PARK WELL WTP ENTRY POINT (WSFID: 00706)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 7/1/2003			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	Offline 11/1/2018 - 11/30/2018	n/a	Y
	Offline 12/1/2018 - 12/31/2018	n/a	Y
	Offline 1/1/2019 - 1/31/2019	n/a	Y
	Offline 2/1/2019 - 2/28/2019	n/a	Y
	Offline 3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.85 PH	Daily
Start Date: 7/1/2003			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	Offline 11/1/2018 - 11/30/2018	n/a	Y
	Offline 12/1/2018 - 12/31/2018	n/a	Y
	Offline 1/1/2019 - 1/31/2019	n/a	Y
	Offline 2/1/2019 - 2/28/2019	n/a	Y
	Offline 3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.75 MG/L	2
Start Date: 1/1/2004			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	Offline 11/1/2018 - 11/30/2018	n/a	Y
	Offline 12/1/2018 - 12/31/2018	n/a	Y
	Offline 1/1/2019 - 1/31/2019	n/a	Y
	Offline 2/1/2019 - 2/28/2019	n/a	Y
	Offline 3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		

Water System Facility: **PLATT LINCOLN WTP ENTRY POINT (WSFID: 00707)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 6/1/2005			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	Offline 1/1/2019 - 1/31/2019	n/a	Y
	Offline 2/1/2019 - 2/28/2019	n/a	Y
	Offline 3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Water System Facility: PLATT LINCOLN WTP ENTRY POINT (WSFID: 00707)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 7/1/2003			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
Offline	1/1/2019 - 1/31/2019	n/a	Y
Offline	2/1/2019 - 2/28/2019	n/a	Y
Offline	3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.1 PH	Daily
Start Date: 7/1/2003			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
Offline	1/1/2019 - 1/31/2019	n/a	Y
Offline	2/1/2019 - 2/28/2019	n/a	Y
Offline	3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.75 MG/L	2
Start Date: 7/1/2003			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
Offline	1/1/2019 - 1/31/2019	n/a	Y
Offline	2/1/2019 - 2/28/2019	n/a	Y
Offline	3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		

Water System Facility: BROAD BROOK WATER TREATMENT PLANT (WSFID: 150)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2002			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Water System Facility: **BROAD BROOK WATER TREATMENT PLANT (WSFID: 150)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2002			
Compliance History:	Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2002			
Compliance History:	Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

Water System Facility: **MERIMERE WATER TREATMENT PLANT (WSFID: 152)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2002			
Compliance History:	Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2002			
Compliance History:	Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Water System Facility: **MERIMERE WATER TREATMENT PLANT (WSFID: 152)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2002			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

Water System Facility: **ELMERE WATER TREATMENT PLANT (WSFID: 153)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2002			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2002			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.15 NTU	186
Start Date: 10/1/2012			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Water System Facility: **BRADLEY HUBBARD WATER TREATMENT PLANT (WSFID: 154)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2002			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
Offline	11/1/2018 - 11/30/2018	n/a	Y
Offline	12/1/2018 - 12/31/2018	n/a	Y
Offline	1/1/2019 - 1/31/2019	n/a	Y
Offline	2/1/2019 - 2/28/2019	n/a	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2002			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
Offline	11/1/2018 - 11/30/2018	n/a	Y
Offline	12/1/2018 - 12/31/2018	n/a	Y
Offline	1/1/2019 - 1/31/2019	n/a	Y
Offline	2/1/2019 - 2/28/2019	n/a	Y
Offline	3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2002			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
Offline	11/1/2018 - 11/30/2018	n/a	Y
Offline	12/1/2018 - 12/31/2018	n/a	Y
Offline	1/1/2019 - 1/31/2019	n/a	Y
Offline	2/1/2019 - 2/28/2019	n/a	Y
Offline	3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2010	
CONSULT WITH THE DEPARTMENT	11/16/2018	11/13/2018
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2018	
ADDRESS CONTAMINATION	1/30/2019	
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	
SUBMIT CCR CERTIFICATION FORM	8/9/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00500	LINCOLN WELL - TOWER EFFLUENT							
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		MWDAS500	500 SOUTH BROAD ST	A			Y	
		MWDBACT020	269 MAIN ST S MERIDN	I	Y			
		MWDBACT021	214 EVANSVILLE AVE	A	Y			
		MWDBACT022	220 COE AVE	A	Y			
		MWDBACT023	528 JOHNSON AVE	A	Y			
		MWDBACT024	583 WEST MAIN ST	A	Y			
		MWDBACT025	168 CHAMBERLAIN HWY	I	Y			
		MWDBACT026	474 CHAMBERLAIN HWY	A	Y			
		MWDBACT027	260 SHERMAN AVE	I	Y			
		MWDBACT028	10 BEE ST	A	Y			
		MWDBACT029	766 NORTH COLONY RD	A	Y			
		MWDBACT030	2090 NO BROAD ST	A	Y			
		MWDBACT030X	1966 NO. BROAD ST	I	Y			
		MWDBACT031	61 PRATT ST	A	Y			
		MWDBACT032	117 PARKER AVE	A	Y			
		MWDBACT033	25 SCHWINKS DR	A	Y			Y
		MWDBACT034	121 GRAVEL ST	A	Y			
		MWDBACT035	1101 EAST MAIN ST	A	Y			
		MWDBACT036	130 HIGH HILL RD	A	Y			Y
		MWDBACT037	22 EAST RD	A	Y			
		MWDBACT038	285 PRESTON AVE	I	Y			
		MWDBACT039	1248 SO. BROAD ST	A	Y			
		MWDBB100	528 JOHNSON AVE	A				Y
		MWDBB200	269 MAIN ST S MERIDN	A				
		MWDBB300	343 WEST MAIN ST	A				Y
		MWDBB400	61 PRATT ST	A				
		MWDBBE00	1285 SO MERIDEN RD	I				Y
		MWDBH100	538 PRESTON AVE	A				
		MWDBH200	285 PRESTON AVE	A				Y
		MWDBH300	390 BEE ST	A				
		MWDBH400	1295 EAST MAIN ST	A				
		MWDBHE00	800 WESTFIELD RD	A				
		MWDEL100	66 KENSINGTON AVE	A				
		MWDEL200	168 CHAMBERLAIN HWY	A				Y

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		MWDEL300	55 MICHAEL DR	A				Y
		MWDEL400	1966 NO BROAD ST	A				
		MWDELE00	658 CHAMBERLAIN HWY	A				
		MWDETP10	1248 SO BROAD ST	A				
		MWDETP20	125 SCOTT ST	A				
		MWDETP30	22 EAST RD	A				
		MWDLC001	16 AKRON ST	A		2		
		MWDLC002	41 CASS ST	A		1		
		MWDLC003	98 HORTON AVE	A		3		
		MWDLC004	37 MONTOWESE DR	A		1		
		MWDLC005	210 CATHERINE DR	A		1		
		MWDLC005OLD	106 NEW CHESHIRE RD	I		N		
		MWDLC006	42 OLD FARM DR	A		1		
		MWDLC007	253 RESERVOIR AV	A		3		
		MWDLC008	333 RESERVOIR AV	A		3		
		MWDLC009	102 SCHOONER LN	A		3		
		MWDLC010	53 FOURTH ST	I		2		
		MWDLC011	38 SURRY DR	A		3		
		MWDLC012	455 WESTFIELD RD	A		1		
		MWDLC013	340 HICKS AV	A		3		
		MWDLC014	76 BAILY AVE	I		2		
		MWDLC015	6 ARTIZAN ST	A		3		
		MWDLC016	99 BRIARWOOD DR	A		3		
		MWDLC017	22 KIM LN	A		2		
		MWDLC018	70 SMITHFIELD AVE	A		3		
		MWDLC019	3 KIRKLAND PL	A		3		
		MWDLC020	27 NORTH ST	I		2		
		MWDLC021	8 OAKLAND CT	A		2		
		MWDLC022	66 NANCY LN	A		3		
		MWDLC023	32 PROSPECT TER	A		3		
		MWDLC024	31 CASTLE DR	A		3		
		MWDLC025	246 GWEN RD	A		3		
		MWDLC026	405 KENSINGTON	A		3		
		MWDLC027	870 NORTH COLONY RD	A		3		
		MWDLC028	660 NORTH COLONY RD	A		2		
		MWDLC029	375 BROWNSTONE RIDGE	I		1		
		MWDLC030	604 GRACEY AVE	A		1		
		MWDLC030OLD	570 BROWNSTONE RIDGE	I		3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		MWDLC031	26 LORI LN	A		1		
		MWDLC031OLD	25 SUZY CT	I		N		
		MWDLC032	93 O'BRIEN DR	A		1		
		MWDLC033	28 NEWTON ST	A		1		
		MWDLC034	6 NORRIE PL	A		3		
		MWDLC035	32 PARKER AV NORTH	A		2		
		MWDLC036	498 PARKER AVE	A		1		
		MWDLC036OLD	215 SOUTH COLONY ST	I		N		
		MWDLC037	145 PETTIT DR	A		1		
		MWDLC037OLD	110 POMEROY AVE	I		3		
		MWDLC038	25 STEVENSON RD	A		3		
		MWDLC040	336 ELM ST	A		3		
		MWDLC041	425 POMEROY AVE	A		3		
		MWDLC042	177 THORPE AVE	A		1		
		MWDLC043	112 STEVENSON RD	A		3		
		MWDLC044	110 DRYDEN DR	A		3		
		MWDLC045	74 CYNROSE PL	A		1		
		MWDLC046	156 METACOMET DR	A		1		
		MWDLC046OLD	3 ABBEY LANE	I		1		
		MWDLC047	26 ALLEN AVE	I		1		
		MWDLC048	92 DRAPER AVE	A		1		
		MWDLC049	91 GOODSPEED AVE	A		3		
		MWDLC050	63 PRESTON AVE	A		3		
		MWDLC051	220 WESTVIEW RD	A		1		
		MWDLC052	312 GRAVEL ST	A		3		
		MWDLC053	34 TREMONT ST	I		1		
		MWDLC054	153 PETTIT DR	A		1		
		MWDLC054OLD	108 WILLIS AVE	I		3		
		MWDLC055	165 NATCHAUG DR	A		3		
		MWDLC056	70 FIESTA HEIGHTS	A		3		
		MWDLC057	10 KEATS RD	A		3		
		MWDLC058	20 MILDRED RD	A		3		
		MWDLC059	438 YALE AVE	A		3		
		MWDLC060	116 VETERAN ST	A		1		
		MWDLC061	76 SAGE HILL RD	A		1		
		MWDLC062	258 NO. WALL ST.	A		3		
		MWDLC062OLD	99 ALANBY DR	I		3		
		MWDLC063	142 GODEK HILL RD.	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		MWDL063OLD	41 SO THIRD ST	I		2		
		MWDL064	71 ARLINGTON NO.	A		1		
		MWDL064OLD	64 MURRAY ST	I		1		
		MWDL065	89 BETHANN CIRCLE	A		1		
		MWDL066	18 STEPHEN DR	A		1		
		MWDL066OLD	26 KENNEDY DR	I		N		
		MWDL067	162 HILLCREST AVE	A		3		
		MWDL068	52 CARL ST	A		3		
		MWDL069	336 CROWN ST	I		3		
		MWDL070	55 SHELLEY RD	A		3		
		MWDL071	102 WILLIAMS ST	A		1		
		MWDL072	104 WHITNEY DR	A		1		
		MWDL072OLD	58 JEROME AVE	I		3		
		MWDL073	132 STEVENSON RD	A		1		
		MWDL074	39 HILLWOOD LA	I		3		
		MWDL075	38 FARM HILL RD	A		3		
		MWDL076	55 EATON AVE	A		3		
		MWDL077	181 DANA LANE	I	Y	3		
		MWDL077OLD	156 METACOMET DR	I		2		
		MWDL078	67 SPERRY LANE	A	Y	1		
		MWDL078OLD	258 N WALL ST	I		3		
		MWDL079	35 FAIR STREET	A	Y	1		
		MWDL079OLD	142 GODEK HILL RD	I		1		
		MWDL080	57 DEBBIE DRIVE	I	Y	N		
		MWDL080OLD	71 ARLINGTON NO	I		1		
		MWDL081	62 FAIRWAY DRIVE	A	Y	1		
		MWDL081OLD	MWDL081	I	Y			
		MWDL082	439 SOUTH CURTIS	A		2		
		MWDL083	30 PINEHURST DR	I		3		
		MWDL084	24 ROCKLEDGE DR	A		3		
		MWDM1000	664 WEST MAIN ST	A				Y
		MWDM2000	412 WEST MAIN ST	A				
		MWDM3000	15 LINCOLN ST	A				
		MWDM4000	142 EAST MAIN ST	A				
		MWDME000	78 RESERVOIR RD	A				
		MWDPL500	540 WEST MAIN ST	A				
		MWDTT001	585 MAIN ST	A				
		MWDTT002	168 CHAMBERLAIN HWY	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		MWDTT003	167 LEWIS AVE	A				
		MWDTT004	105 MILLER ST	A				
		MWDTT005	281 EAST MAIN ST	A				
		MWDTT006	50 YALE AVE	A				
		MWDTT007	61 TULIP DR	A				
		MWDTT008	692 EAST MAIN ST	A				
		MWDTT009	1966 NO BROAD ST	A				
		MWDTT010	553 NORTH COLONY RD	A				
		MWDTT011	341 SO BROAD ST	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	MERIMERE WTP ENTRY POINT	3	EP - MERIMERE	A				
00701	ELMERE WTP ENTRY POINT	3	EP - ELMERE	A				
00702	BROAD BROOK WTP ENTRY POINT	3	EP - BROAD BROOK	A				
00703	BRADLEY HUBBARD WTP ENTRY POINT	3	EP - BRADLEY HUBBARD	A				
00704	EVANSVILLE WTP ENTRY POINT	3	EP - EVANSVILLE	A				
00705	MULE WELL WTP ENTRY POINT	3	EP - MULE WELL	A				
00706	COLUMBUS PARK WELL WTP ENTRY POINT	3	EP - COLUMBUS PARK	A				
00707	PLATT LINCOLN WTP ENTRY POINT	3	EP - PLATT LINCOLN	A				
1355	MULE WELL	2	MULE WELL	A				
1356	COLUMBUS PARK WELL	2	COLUMBUS PARK WELL	A				
1357	PLATT WELL	2	PLATT WELL	A				
1358	LINCOLN WELL	2	LINCOLN WELL	A				
1359	EVANSVILLE AVENUE WEST WELL	2	EVANSVILLE AVENUE WE	A				
1360	EVANSVILLE AVENUE EAST WELL	2	EVANSVILLE AVENUE EA	A				
150	BROAD BROOK WATER TREATMENT PLANT	5	CFE - BROAD BROOK TP	A				
151	PLATT LINCOLN TREATMENT STATION	5	IESWTR - PLATT EP	A				
152	MERIMERE WATER TREATMENT PLANT	5	CFE - MERIMERE WTP	A				
153	ELMERE WATER TREATMENT PLANT	5	CFE - ELMERE WTP	A				
154	BRADLEY HUBBARD WATER TREATMENT PLANT	5	CFE - BRADLEY WTP	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
155	EVANSVILLE WATER TREATMENT PLANT	5	IESWTR - EVANSVIL EP	A				
156	MULE TREATMENT STATION	5	IESWTR - ENTRY POINT	A				
157	COLUMBUS PARK WELL TREATMENT STATION	5	IESWTR - COLUMBUS EP	A				
2139	BRADLEY HUBBARD RESERVOIR	1	BRADLEY HUBBARD RES	A				
2140	KENMERE RESERVOIR	1	KENMERE RESERVOIR	A				
2141	MERIMERE RESERVOIR	1	MERIMERE RESERVOIR	A				
2142	BROAD BROOK RESERVOIR	1	BROAD BROOK RES	A				
2143	HALLMERE RESERVOIR	1	RESERVOIR	A				
2144	STOCKING BROOK DIVERSION	1	RESERVOIR	A				
2145	ELMERE RESERVOIR	1	ELMERE RESERVOIR	A				
2146	MALONEY CANAL DIVERSION	1	RESERVOIR	A				
2147	MCKONE CANAL DIVERSION	1	RESERVOIR	A				
30040	BRADLEY HUBBARD RESERVOIR							
30041	MERIMERE RESERVOIR							
30042	ELMERE RESERVOIR							
30043	BROAD BROOK RESERVOIR							
45118	INTERCONNECTION - RWA							
49588	JOHNSON AVE TANK							
49590	CARPENTER AVE ATMOSPHERIC TANK							
49592	FLEMING ROAD TANK							
49594	ELMERE TANK							
49596	MERIMERE TANK							
49598	COLLINSDALE TANK 1							
49600	COLLINSDALE TANK 2							
49602	SCHWINKS HILL TANK 1							
49604	SCHWINKS HILL TANK 2							
49606	CARPENTER AVE PRESSURE TANK 1							
49608	CARPENTER AVE PRESSURE TANK 2							
49610	BROAD BROOK CLEARWELL							
49612	BRADLEY-HUBBARD TANK							
49614	FINCH AVE PUMP STATION							
49616	JOHNSON AVE PUMP STATION							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
49618	EAST ROAD PUMP STATION							
49620	CARPENTER AVE PUMP STATION							
49622	PARKER AVE PUMP STATION							
49624	SCHWINK DRIVE PUMP STATION							
49626	COLLINSDALE PUMP STATION							
53151	JOHNSON AVE EAST TANK							
53153	JOHNSON AVE WEST TANK							
59159	PLATT LINCOLN CLEARWELL							
59163	EVANSVILLE CLEARWELL							
59916	BROAD BROOK WTP BACKWASH SUPPLY TANK							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: CLASS 3 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
WAZ, DENNIS	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2021 12/31/2020
GESNER, LANE W.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2019 12/31/2020
ANTONIO, BRUCE M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020
WELCH, JAMIE W.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
STANDISH, PETER	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2020
BENDER, ERIC G.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2019
PELLEGRINO, DANIEL	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2019 6/30/2020
DEXTER, DOUGLAS	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020
GALLAGHER, JEFFREY H.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2020
ARRIGONI, PETER J.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2019
ROBERTS, CHAD M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2019 9/30/2019
LABUTIS, THOMAS J.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020
TERAPANE, ROBERT	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2020
GONZALEZ, LUIS E.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2019
FORNACIARI, JR., JOSEPH	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2020
GRADY, SEAN P	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2021 12/31/2020

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: CLASS 3 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
CARON, SCOTT A	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2020
		WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2021

Water System Facility: BROAD BROOK WATER TREATMENT PLANT (WSF ID: 150)

Facility Classification: CLASS 4 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
GRADY, SEAN P	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020
PELLEGRINO, DANIEL	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2020
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2019
ROBERTS, CHAD M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2019
WAZ, DENNIS	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2020
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2021

Water System Facility: PLATT LINCOLN TREATMENT STATION (WSF ID: 151)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
GRADY, SEAN P	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020
		WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2021
PELLEGRINO, DANIEL	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2020
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2019
ROBERTS, CHAD M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2019
WAZ, DENNIS	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2020
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2021

Water System Facility: MERIMERE WATER TREATMENT PLANT (WSF ID: 152)

Facility Classification: CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
PELLEGRINO, DANIEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2020
ROBERTS, CHAD M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2019
WAZ, DENNIS	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2020
GRADY, SEAN P	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020
		WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2021

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Certified Operator Information

Water System Facility: ELMERE WATER TREATMENT PLANT (WSF ID: 153)

Facility Classification: CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
PELLEGRINO, DANIEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2019 6/30/2020
ROBERTS, CHAD M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2019 9/30/2019
WAZ, DENNIS	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020 9/30/2021
GRADY, SEAN P	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2021 12/31/2020

Water System Facility: BRADLEY HUBBARD WATER TREATMENT PLANT (WSF ID: 154)

Facility Classification: CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
ROBERTS, CHAD M.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2019 6/30/2019
PELLEGRINO, DANIEL	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2019 6/30/2020
WEST, ANTHONY	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2019 12/31/2021
WAZ, DENNIS	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020 9/30/2021
GRADY, SEAN P	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2021 12/31/2020

Water System Facility: EVANSVILLE WATER TREATMENT PLANT (WSF ID: 155)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
GRADY, SEAN P	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2020 3/31/2021
PELLEGRINO, DANIEL	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2019 6/30/2020
ROBERTS, CHAD M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2019 9/30/2019
WAZ, DENNIS	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020 9/30/2021

Water System Facility: MULE TREATMENT STATION (WSF ID: 156)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
PELLEGRINO, DANIEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2019 6/30/2020

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Certified Operator Information

Water System Facility: MULE TREATMENT STATION (WSF ID: 156)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
JANUSONIS, STEVEN J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019 3/31/2020
ROBERTS, CHAD M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2019 9/30/2019
WAZ, DENNIS	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020 9/30/2021
GRADY, SEAN P	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2020 3/31/2021

Water System Facility: COLUMBUS PARK WELL TREATMENT STATION (WSF ID: 157)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
PELLEGRINO, DANIEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2019 6/30/2020
ROBERTS, CHAD M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2019 9/30/2019
WAZ, DENNIS	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020 9/30/2021
GRADY, SEAN P	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2020 3/31/2021

Contact Information

Name				Organization			Job Title		
Mr. Dennis Waz				Meriden Water Division			Super. of Operations		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
117 Parker Ave						Meriden		CT	06450
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-630-4256			203-630-4285			203-238-1911	dwaz@meridenct.gov		

Contact Role(s): Administrative Contact

Name				Organization			Job Title		
Mr. Timothy Coon				City of Meriden			City Manager		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
142 East Main St.						Meriden		CT	06450
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-630-4123			203-630-4274				tcoon@meridenct.gov		

Contact Role(s): Legal Contact

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16,633	950	20		5

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.